

Essex County Fire & Rescue Service

Mr Adam Eckley, MBA, M.I.Fire.E
Acting Chief Fire Officer and Acting Chief Executive

For the attention of Mr Gary O'Shea
Brentwood Borough Council
Licensing Office
Town Hall
Ingrave Road
Brentwood
Essex
CM15 8AY



BASILDON SERVICE DELIVERY POINT



Fire Station
Broadmayne
Basildon

SS14 1EH

☎ 01376 576700

✉ basildonsdp@essex-fire.gov.uk

Date: 16th February 2016
Our Ref: 51/100091435713
Your Ref: Letter
Enquiries to: Fire Safety Officer Garry Owles



Dear Sir

Local Government (Miscellaneous Provisions) Act 1982 Street Trading and Market Policy Consultation

I refer to your correspondence dated 22nd January 2016 regarding the review of the Street Trading and Market Policy.

As a result the content of the document has now been examined and the following minor amendment is suggested:

Section 4.1 (k)

Delete "gas cylinders should be laid down".

Add "gas cylinders (LPG) should be stored / used in the fully upright position at all times. The cylinders should where necessary be tethered in that position to a rigid supporting structure to prevent the possibility of being inadvertently moved or overturned.

Other than that stated above Essex County Fire & Rescue Service has no further observations to make on the proposed policy on this occasion.

Yours faithfully

G. Owles
Fire Protection Inspecting Officer
West Area Command